

Laboratory Report

NYE Report #: 2404035-30203

June 17, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Arlington Csd; Arthur S May School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 12, 2024. New York Environmental analyzed the samples on June 13, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240612P012	1	Kitchen Dishwash 3-Bay Left-SK, Initial	0.001	<0.001	mg/L	
240612P013	2	Kitchen Dishwash 3-Bay Right-SK, Initial	0.001	<0.001	mg/L	
240612P014	3	Cafeteria-BF, Initial	0.001	<0.001	mg/L	
240612P015	4	Cafeteria-WF, Initial	0.001	<0.001	mg/L	
240612P016	5	Hall by Room 102-SK, Initial	0.001	<0.001	mg/L	
240612P017	6	Hall by Room 110 Left-WF, Initial	0.001	<0.001	mg/L	
240612P018	7	Hall by Room 108 Right-WF, Initial	0.001	<0.001	mg/L	
240612P019	8	library-SK, Initial	0.001	<0.001	mg/L	
240612P020	9	Hall by Room105 Right-WF, Initial	0.001	0.004	mg/L	
240612P021	10	Hall by Room105 Left-WF, Initial	0.001	0.006	mg/L	H
240612P023	12	Health Office Exam Room-SK, Initial	0.001	0.005	mg/L	
240612P024	13	Health Office Exam Room-SPY, Initial	0.001	0.004	mg/L	
240612P025	14	Main Hallway Left Fountain 103-WF, Initial	0.001	0.001	mg/L	
240612P026	15	Main Hallway Right Fountain-WF, Initial	0.001	0.004	mg/L	
240612P027	16	Hall by Boy's Locker Room-SK, Initial	0.001	<0.001	mg/L	
240612P028	17	Hall by Girl's Locker Room-SK, Initial	0.001	0.001	mg/L	
240612P029	18	South End Hallway-WF, Initial	0.001	0.005	mg/L	
240612P030	19	South End Hallway-SK, Initial	0.001	<0.001	mg/L	
240612P031	20	South End Hallway-SK, Initial	0.001	<0.001	mg/L	
240612P032	21	Room 205-SK, Initial	0.001	<0.001	mg/L	
240612P033	22	Room 207A-SK, Initial	0.001	<0.001	mg/L	
240612P034	23	Hall by Room 210 Left-WF, Initial	0.001	0.014	mg/L	H
240612P035	24	Hall by Room 210 Right-WF, Initial	0.001	0.007	mg/L	H
240612P036	25	Room 211-SK, Initial	0.001	<0.001	mg/L	
240612P037	26	Room 212-SK, Initial	0.001	<0.001	mg/L	
240612P038	27	Room 214-SK, Initial	0.001	<0.001	mg/L	

Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240612P039	28	Hall by Room 216 Left-WF, Initial	0.001	<0.001	mg/L	
240612P040	29	Hall by Men's Faculty Bathroom Right-WF, Initial	0.001	0.001	mg/L	
240612P041	30	Hall by Room 226 Left-SK, Initial	0.001	0.004	mg/L	
240612P042	31	Hall by Room 226 Right-BF, Initial	0.001	<0.001	mg/L	
240612P043	32	Hall by Room 226 Right-WF, Initial	0.001	<0.001	mg/L	
240612P044	33	Basement Old Custodial Break Room-SK, Initial	0.001	0.010	mg/L	H
240612P045	34	Faculty Room Unit Left-SK, Initial	0.001	0.030	mg/L	H
240612P046	35	Faculty Room Unit Middle-SK, Initial	0.001	0.026	mg/L	H
240612P047	36	Faculty Room Unit Right-SK, Initial	0.001	0.018	mg/L	H
240612P048	37	Faculty Room-SK, Initial	0.001	<0.001	mg/L	
240612P049	38	Basement Music Rehearsal Room-SK, Initial	0.001	0.012	mg/L	H
240612P050	39	Basement Music Rehearsal Room-WF, Initial	0.001	0.023	mg/L	H
240612P051	40	Basement Music Office-SK, Initial	0.001	0.015	mg/L	H
240612P052	41	Basement Music Office-WF, Initial	0.001	0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.